

CHONGQING BORIDA CONSTRUCTION CO.,LTD

C O A

Product: Expansion agent

Trademark:



Quantity: 5/Ton

Production Code:

190105

Model: BD-UEA

Testing Standard:

GB/T 23439-2017

Package: 50kg/Bag

Date:

2019.1.28

NO	Experimental project	Standard	Result	R/W	
1	Fineness	Surface area/ (m ² /kg)	≥200	230	R
		1.18mm Filter Remaining/%	≤0.5	0.3	R
2	Setting time	Initial Setting/min	≥45	122min	R
		Finally Setting/min	≤600	534min	R
3	Limit Expansion Rate%	In Water 7d	≥0.035	0.052	R
		In Air 21d	≥-0.015	0.019	R
4	Compressive Strength MPa	7d	≥22.5	22.55	R
		28d	≥42.5	42.8	R
5	Conclusion: After inspection, BD-UEA meets the standard index value of GB/T 23439-2017 and is allowed to leave the factory.				
Remarks					
1: Dosage: 8%					
2: Standard: GB/T 23439-2017 《Expansion Agent》					

Review:

